

Residential Water User Cross Connection Hazards

Bathrooms and Kitchens

Did you know...

Your water can become contaminated if connections to your plumbing system are not properly protected.

The purpose of the local cross connection control program, as required by state plumbing code and regulations, is to ensure that everyone in the community has safe, clean drinking water.

Public Health and Safety...

To avoid contamination, backflow preventers are required by state plumbing codes wherever there is an actual or potential hazard for cross contamination. The Wisconsin Department of Natural Resources requires all public water suppliers to maintain an ongoing cross connection control program involving public education, onsite inspection and possible corrective actions by building owners if required.

More Information

WI Department of Commerce
www.commerce.state.wi.us/

WI Department of Natural Resources
www.dnr.wi.gov

Environmental Protection Agency (EPA)
www.epa.gov

Cross Connection Control/Backflow Prevention
www.hydrodesignsinc.com



Manitowoc Public Utilities
1303 South 8th Street
Manitowoc, WI 54220
(920) 683-4600 Phone

Contract
Operator for:



Village of Reedsville
Plant Phone
(920) 754-4094
(920) 754-4103 Fax

COREY HOPPENRATH utilities@reedsville.org
Water/Wastewater Operator



Contract
Operator for:




Manitowoc Public Utilities
1303 South 8th Street
Manitowoc, WI 54220
(920) 683-4600 Phone

Village of Reedsville
Plant Phone
(920) 754-4094
(920) 754-4103 Fax

COREY HOPPENRATH utilities@reedsville.org
Water/Wastewater Operator

Maintaining the integrity of your
public drinking water system.



What is a Cross Connection?

A cross connection is an actual or potential connection between the safe drinking water (potable) supply and a source of contamination or pollution. State plumbing codes require approved backflow prevention methods to be installed at every point of potable water connection in use. Cross connections must be properly protected or eliminated.

How does contamination occur?

When you turn on your faucet, you expect the water to be as safe as when it left the treatment plant. However, certain hydraulic conditions left unprotected within your plumbing system may allow hazardous substances to contaminate your own drinking water or even the public water supply.

Water normally flows in one direction. However, under certain conditions, water can actually flow backwards; this is known as backflow. There are two situations that can cause water to flow backward: back siphonage and back pressure.

Back Siphonage

Back siphonage may occur due to a loss of pressure in the municipal water system during a fire fighting emergency, a water main break or system repair. This creates a siphon in your plumbing system which can draw water out of a sink or bucket and back into your water or the public water system.



Back Pressure

Back pressure may be created when a source of pressure (such as a boiler) creates a pressure greater than the pressure supplied from the public water system. This may cause contaminated water to be pushed into your plumbing system through an unprotected cross connection.

In the Bathroom—Hand-held Shower Fixture


The hand-held shower fixture is compliant if:

- When showerhead is hanging freely, it is at least one inch above top of the flood level rim of the receptor (tub).
- Complies with ASSE#1014.
- Has the ASME code 112.18.1 stamped on the handle.




In the Bathroom—Toilet Tanks

There are many unapproved toilet tank fill valve products sold at common retailers which do not meet the state plumbing code requirements for backflow prevention.



- Look for the ASSE #1002 standard symbol on the device and packaging.
- Replace any unapproved devices with an ASSE #1002 approved anti-siphon ballcock assembly. Average cost is typically \$12 to \$22 at home improvement stores.
- Verify overflow tube is one inch below critical level (CL) marking on the device.

In the Kitchen



Hoses and water treatment devices may create a potential backflow hazard if not properly isolated with backflow prevention methods.

Insights to protect your drinking water

Do...

- Keep the ends of hoses clear of all possible contaminants.
- Make sure dishwashers are installed with a proper "air gap" device.
- Verify and install a simple hose bibb vacuum breaker on all threaded faucets around your home.
- Make sure water treatment devices such as water softeners have the proper "air gap", which is a minimum of one inch above any drain.

Don't...

- Submerge hoses in buckets, pools, tubs, sinks or ponds.
- Use spray attachments without a backflow prevention device.
- Connect waste pipes from water softeners or other treatment systems directly to the sewer or submerged drain pipe. Always be sure there is a one inch "air gap" separation.



Contract
Operator for:

